

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

NO. 8912

Dated- 19.02.2026

It is certified that an inspection team headed by Dr. S. K. Chak, Chief Medical Officer Bhadohi from Public Health Department PHED Bhadohi, inspected the Om Public School, Gt Road, Vittahlpur, Chhatmi, Gopiganj, Bhadohi on date 14-02-2026 and on the basis of Water Test Report (Attached) bearing no. TC-13627 and test Report/Exe.Eng.Com.Divi./Chemical Test/260/2025-26 dated 18/02/2026 of District water Analysis Laboratory UP Jal Nigam (Rural) MIG II 11 & 12 Jamunipur colony, Bhadohi-221409, Certified that the Om Public School, Gt Road, Vittahlpur, Chhatmi, Gopiganj, Bhadohi has safe drinking water facilities for the students and members of the institution. School is also maintains the Hygienic Sanitation Condition in the school building and the campus as per norms prescribed by the Central/State/U .T. Govt.

This certificate is valid till—15/02/2027

Signature with seal


Name : Dr. S. K. Chak

Designation : Chief Medical Officer

Name & Address of the Office/Department: Office of
CMO, Sarpanch, G.P. Bhadohi
**Chief Medical Officer
Bhadohi**

To,

The Manager,
Om Public School,
Gt Road, Vittahlpur, Chhatmi,
Gopiganj, Bhadohi


MANAGER
Om Public School
Vittahlpur, Chhattami, Gopiganj
S.R.N. Bhadohi


Sunil Dutta Tripathi
Principal
OM PUBLIC SCHOOL
(Affiliated to CBSE 10+2, New Delhi)
Aff.No. 2132541, School Code-71195
G.T. Road, Bitthalpur, (Chhatami)Gopiganj
Bhadohi, 221303 (U.P.)



Test Report

District water Analysis Laboratory UP Jal Nigam(Rural)

MIG II 11&12 Jamunipur Colony

Sant Ravidas Nagar (Bhadohi)-221409



TC-13627

Report No.	Test Report / Exe .Eng. Con .Divi. / Chemical Test /260/2025-26	Issue Date	18/02/2026	Page No	1 of 2
------------	---	------------	------------	---------	--------

Customer Details

Office Name and Address	OM PUBLIC SCHOOL ,G.T. ROAD, VITTHALPUR (CHHATAMI), GOPIGANJ BHADOHI (U.P.) - 221303
Ref Letter No & Date	NA

Basic details of sample

District	Sant Ravidas Nagar Bhadohi	Block	Deegh
Gram Panchyat	Chhatami	Village	Chhatami
Habitation	-	Location	School Ground
Water Source	Drinking Water	Sample Code	B/26/02/699
Quantity of Sample	1.0 Ltr	Date Of S.C.	16/02/2026
Receiving Date	16/02/2026	S. Collector	Ajay Kumar Mishra
Sample Depositor	Ajay Kumar Mishra	Sampling Method Used	IS:17614:P-1:2021
Analysis Start Date	16/02/2026	Analysis Completion Date	18/02/2026

Environmental Condition

Temperature	25 ± 3°C	Humidity	50 ± 15%
-------------	----------	----------	----------

Technical Data of Analysis

S.No	Analyzed Parameters	Unit of Measurement	Observed value	Limits of IS: 10500-2012		Reference Method of Analysis
				Desirable Limit (Max)	Permissible Limit in the Absence of Alternate Source (Max)	
1.	pH	—	7.10	6.5-8.5	No relaxation	IS : 3025 (Part 11) - 2022
2.	Colour	Hazen	<5	5	15	APHA 24th Edition 2120 Colour Method B Platinum Cobalt Visual Comparison-2023
3.	Odour	—	Agreeable	Agreeable	Agreeable	IS 3025 (Part 5) : 2022
4.	Taste	—	Agreeable	Agreeable	Agreeable	IS : 3025 (Part 8) - 2023
5.	Turbidity	NTU	0.83	01	05	IS : 3025 (Part 10) - 2024
6.	Total Dissolve Solids	mg/l	128.0	500	2000	IS : 3025 (Part 16) - 2023
7.	Total Alkalinity (as CaCO ₃)	mg/l	124.0	200	600	IS 3025 (Part 23) : 2023
8.	Total Hardness(as CaCO ₃)	mg/l	144.0	200	600	IS 3025 (Part 21) : 2023
9.	Calcium as Ca	mg/l	30.4	75	200	IS 3025 (Part 40) : 2024
10.	Magnesium as Mg	mg/l	16.55	30	100	IS 3025 (Part 46) : 2023
11.	Sulphate (as SO ₄)	mg/l	1.27	200	400	APHA 24th Edition – 4500-SO ₄ Method E (Turbidity Method ,2023)
12.	Nitrate(as NO ₃)	mg/l	10.05	45	No relaxation	APHA 24th Edition – 4500-NO ₃ Method B (UV Screening Method ,2023)
13.	Iron(as Fe)	mg/l	0.09	1.0	No relaxation	APHA 24th Edition – 3500- Fe Method B

					(Phenanthroline 2023)
14	Fluoride	mg/l	0.05	1.0	1.50
					APHA 24th Edition 4500-F Method C (Electrode Method, 2023)

*BDL-Below Detection Limit.

- Note-
- 1 This certificate refers only to the particular samples submitted for testing
 - 2 This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract
 - 3 The test results reported in this certificate are valid at the time of and under the stated conditions of measurements
 - 4 Sample will be stored up to 7 days (in case of non perishable items only) from the date of issue of tests reports

Prepared by:
Manish Kumar Yadav
(Deputy Technical Manager)

Manish Kumar



Laboratory contact details :-Name- Mahendra Pal
Mo. No 9919087307
Email ID:-mahendrapal4491@gmail.com

*** END OF THE REPORT***



Test Report

District water Analysis Laboratory UP Jal Nigam(Rural)

MIG II 11&12 Jamunipur Colony

Sant Ravidas Nagar (Bhadohi)-221409

Report No 260/2025-26 Test Report / Exe. Eng. Con. Divi. / Microbial Test Issue Date 18/02/2026 Page No 01

Customer Details

Office Name and Address OM PUBLIC SCHOOL, G.T. ROAD, VITTHALPUR (CHHATAMI), GOPIGANJ BHADOHI (U.P.) - 221303
Ref Letter No & Date NA

Basic details of sample

Distnct	Sant Ravidas Nagar Bhadohi	Block	Deegh
Nagar Panchyat	Bhadohi	Village	Chhatami
Habitation	-	Location	School Ground
Water Source	Drinking Water	Sample Code	B/26/02/699
Quality of Sample	1.0 Ltr	Date Of S.C.	16/02/2026
Receiving Date	16/02/2026	S. Collector	Ajay Kumar Mishra
Sample Depositor	Ajay Kumar Mishra	Sampling Method Used	IS:1622-2003 IS:17614-P-1:2021
Analysis Start Date	16/02/2026	Analysis Completion Date	18/02/2026

Environmental Condition

Temperature	25 ± 3 C	Humidity	50 ± 15%
-------------	----------	----------	----------

Technical Data of Analysis

S. No	Parameters	Observed value	Unit	Limits of IS: 10500-2012		
				Desirable Limit (Max)	Permissible Limit in the Absence of Alternate Source (Max)	Reference Method of Analysis
1.	Total coli form	E. coli	NIL	NIL	NIL	IS 15185:2016
		T. Coliform	NIL			
2.	Chloride (as Cl)	3.99	(mg/l)	250.0	1000.0	IS 3025 (Part 32) : 2023

UNC = Uncountable

Tested by:

Mahendra Kumar Yadav

Mahendra Kumar Yadav

Laboratory contact details: - Name- Mahendra Pal
Mo No 9919087307
Email ID -mahendrapal4491@gmail.com



*** END OF THE REPORT***